BV LCIE CHINA Number N° 1966AS10GYB33100

ATTESTATION
of conformity with European Directives

Product:	**MCB**
Reference	**GYM8 Series**
Issued to	**ZHEJIANG GEYA ELECTRICAL CO., LTD**
Address	**WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN 325603 YUEQING,ZHEJIANG- CHINA**
Manufacturer	**ZHEJIANG GEYA ELECTRICAL CO., LTD**
Technical characteristics	**Type B,C and D** **Ue=220V/380V,230V/400V,240V/415V ~(1P);380V,400V,415V ~(2P;3P;4P)** **In=1A;2A;3A;4A;5A;6A;10A;13A;15A;16A;20A;25A;32A;40A;50A;63A** **Ics=Icn=Icn1=4500A and 3000A** **Energy limit class: 1(Type B and C)** **(according to EN 60898-1)** **Grid distance: 35mm** **Ui=500V** **Uimp=4kV** **Screw diameter of load terminal =4,9mm**

The submitted sample of the above equipment has been tested for CE marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	*Report number*	*Report date*
EN 60898-1:2019	**B190047**	**17/10/2019**

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The CE marking may be affixed if all relevant and effective European Directives with CE are applicable

Shanghai (P.R. China),), October 25th, 2019.

Chaojie CHEN
Product Line Manager

CE

LCIE CHINA COMPANY LIMITED

This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road, CaoHejing Songjiang High-Tech Park, Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email:contact@cn.bureauveritas.com