IEC IECEE CB SCHEME

Ref. Certif. No.

CN47986

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Current Relay
Name and address of the applicant	ZHEJIANG GEYA ELECTRICAL CO.,LTD Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China
Name and address of the manufacturer	ZHEJIANG GEYA ELECTRICAL CO.,LTD Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China
Name and address of the factory *Note: When more than one factory, please report on page 2*	ZHEJIANG GEYA ELECTRICAL CO.,LTD Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China
Ratings and principal characteristics	Uimp:2.5kV;Ui:250V;Uc:250V;Ie:2.5A;Ith:10A;Utilization category:AC-15
Trademark (if any)	GEYA
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	GRI8-□/□;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2016(4th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	(2019)FQIIDQ-0645

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Sep.10,2019

Signature: Lu Mei

CQC

CB 0053814