Ref. Certif. No.

CN57794

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Current Relay
Name and address of the applicant	ZHEJIANG GEYA ELECTRICAL CO.,LTD Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, P.R.China
Name and address of the manufacturer	ZHEJIANG GEYA ELECTRICAL CO.,LTD Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, P.R.China
Name and address of the factory Note: *When more than one factory, please report on page 2*	ZHEJIANG GEYA ELECTRICAL CO.,LTD Floor3-5， Building 5, No.91, Binjiang Road, Guantou Village, Beibaixiang Town, Leqing City, Zhejiang Province,P.R.China
Ratings and principal characteristics	Uimp:2.5kV;Ui:250V;Ue:250V; Ie:2.5A;Ith:10A;Utilization Category:AC-15;IP20
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	GRI8-05A,GRI8-05B;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2016(4th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	(2022)FQIIDQ-0888

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Sep.08,2022

Signature: 谢肇煦
Xie ZhaoXu

CB 0068602