	Ref. Certif. No.
	HU-004345

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Moulded case circuit breaker
Name and address of the applicant	Zhejiang GEYA Electrical Co.,Ltd Wenzhou Brige Industrial Zone,Beibaixiang Town, Yueqing City, Zhejiang P.R. China
Name and address of the manufacturer	Zhejiang GEYA Electrical Co.,Ltd Wenzhou Brige Industrial Zone,Beibaixiang Town, Yueqing City, Zhejiang P.R. China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Zhejiang GEYA Electrical Co.,Ltd Wenzhou Brige Industrial Zone,Beibaixiang Town, Yueqing City, Zhejiang P.R. China
Ratings and principal characteristics	Cat. A; Reference temperature: +40 °C; Ui=1000V; Uimp=12kV; 3P, 3P+N, 4P; Ue:AC400/415V,AC500V,AC690V; 50/60Hz; In=630A, 700A, 800A, 900A, 1000A, 1250A
Trademark / Brand (if any)	GEYA
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	GYCM8-1250M, GYCM8-1250H, GYCM8-1000M, GYCM8-1000H, GYCM8-900M, GYCM8-900H, GYCM8-800M, GYCM8-800H, GYCM8-700M, GYCM8-700H, GYCM8-630M, GYCM8-630H
Additional information (if necessary may also be reported on page 2)	N/A
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN232JIO 001

This CB Test Certificate is issued by the National Certification Body

TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-04-03

Signature: Wencai Zhang

10/061SMD 2022-07 rke-fix

Disclaimer: This is an electronically released document. The authenticity can be verified on the IECEE Website "http://certificates.iecee.org" (1.29 / 0)